



Wheelabrator Saugus Inc.

A Waste Management Company

100 Salem Turnpike
Saugus, MA 01906
(781) 233-7600 Tel
(781) 231-2793 Fax

Submitted electronically via netDMR

September 11, 2012

U.S. Environmental Protection Agency
Water Technical Unit (SMR-04)
5 Post Office Square – Suite 100
Boston, MA 02109-3912

RE: Wheelabrator Saugus Inc.
August 2012 DMR
NPDES Permit No. MA0028193

Dear Sir/Madam:

Wheelabrator Saugus Inc. (WSI) respectfully submits the August 2012 Discharge Monitoring Report(s) (DMR) for the facility located at 100 Salem Turnpike, Saugus, MA 01906.

Via netDMR, WSI has electronically provided the DMR to the Agency and MA Department of Environmental Protection, Bureau of Waste Prevention (NERO). If you have any questions, or would prefer a hardcopy of this submittal, please do not hesitate to contact me or the facility's Environmental Manager, at 781.233.7600.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified Personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information is submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sincerely,

Eric Lucier
Plant Manger

cc: MA DEP Bureau of Waste Prevention (NERO) (via netDMR)
MA DEP Division of Watershed Management Surface Water Discharge Permit Program (Hardcopy)
Jim Connolly (WTI) (via email), Matt Hughes (WSI) (via email)
Dana Buske, Tech Environmental (via email)
Frank Giacalone (Saugus B.O.H.)

AUGUST 2012

Flow Limit	Highest Daily Hourly Average Intake Temperature	Total number of Calendar Days Flow Limit was in effect
43.2 MGD	< 65 °F	*Not in effect "9"
50 MGD	65 – 70 °F	*Not in effect "9"
60 MGD	> 70 °F	31

**Per Part 1A, footnote 3 of NPDES Permit #MA0028193, if a particular flow limit was not in effect for a particular month, the no data indicator code of "9", shall be entered. Therefore, since the 43.2 MGD and 50 MGD flow limits were not in effect, the indicator code of "9" is reflected in the table above.*